

IS 01 Interpretation of Clause 9
IEC 61347-1: 2000 First edition
Lamp controlgear - Part 1: General and safety requirements

INTERPRETATION SHEET

The restriction "However, if a lamp controlgear has an earthing terminal, this terminal shall only be used for earthing the lamp controlgear" is not applicable for independent lamp controlgear.

Independent lamp controlgear may have earthing terminals which are not only for their own earthing.

